

AQUAMEAS INST PVT LTD		DATA SHEET FOR CAPACITANCE TYPE LEVEL MEASURING SYSTEM	Doc No	INST/DS/08	
				REV	0
	Date		#####		
Checked by	DSS				
Approved by	KPJ				
Revision details					
Sr No	Particular	Description			
1	Service	level measurement			
2	Quantity and Range	upto 10 Mtrs			
3	Mounting	Top Mounted			
4	Zero span adjustment	Available			
6	Accuracy of measuring Loop	± 1% of full scale			
7	Out Put	4-20 mA			
8	Disply unit	Digital pannel meter with Hi & Low Alarm			
Note :					